

Assessing the need for neutralizing KCl filter testing aerosol

Original

Assessing the need for neutralizing KCl filter testing aerosol / Tronville, PAOLO MARIA; Rivers, R; Ellena, M.. - ELETTRONICO. - (2009).

Availability:

This version is available at: 11583/2290769 since:

Publisher:

Published

DOI:

Terms of use:

openAccess

This article is made available under terms and conditions as specified in the corresponding bibliographic description in the repository

Publisher copyright

(Article begins on next page)



AAAR 28th Annual Conference

Presented by the **American Association for Aerosol Research**

[Home](#) > [Abstracts](#) > [Paolo Tronville](#)

Paolo Tronville

Assessing the need for neutralizing KCl filter testing aerosol

PAOLO TRONVILLE (1), Richard Rivers (2), Massimo Ellena (3)

(1) Politecnico di Torino, Dipartimento di Energetica, Corso Duca degli Abruzzi 24, 10129 Turin, Italy (2) EQS, inc., 1262 Bassett Ave., Louisville, KY 40204, USA (3) TEXA S.r.l., Via Simone Gribaudo, 22/A, 10034 Chivasso (TO), Italy

Abstract Number: 818

Last modified: April 24, 2009

Preference: Poster Presentation

Working Group: Control Technology

Abstract

Tests for particle capture by fibrous filters should mimic the charge conditions of natural aerosols. These normally exist in approximate Boltzmann equilibrium, where equal numbers of positive and negative charges are distributed on the aerosol particles, and those numbers are small. To mimic this condition in a generated test aerosol, experimenters have employed aerosol neutralizers, chiefly those using radioactivity and those using bipolar corona discharges. Corona neutralizers can handle larger aerosol flows, and avoid licensing problems. Neutralizers are designed to flood the aerosol with equal numbers of positive and negative ions. Accomplishing this by using bipolar corona neutralizers is a sensitive control problem. A simple instrument - the Faraday cage aerosol charge detector - can measure the net charge on an aerosol cloud continuously. If the distribution of particle diameters and total particle count are also measured, one can determine the degree to which the charge on the aerosol deviates from the theoretically calculated Boltzmann Equilibrium. We report such measurements made on DEHS and KCl aerosols generated by some filter test procedures, to determine whether neutralization is actually needed for these aerosols. The loss of particles in various types of feed tubing is also reported.

[home](#) | [overview](#)
[program](#) | [submission](#) | [organization](#)

[Top](#)